XYP 2: Pneumatic test unit for controllers

For simulating an open or a closed control loop and for checking the functions of all *centair* controllers. The transducer and the setpoint's remote adjuster are simulated. Conforms to the regulations on pressure equipment (97/23/EG Art. 3.3).

Housing and insert of thermoplastic: front door of transparent thermoplastic; front plate with adjuster knobs and three manometers; one empty housing for inserting the test object; includes a bag of installation material; compressed-air connections Rp ½ female thread. Various connection pieces are available for use in laboratory, workshop and testing the plant.

Туре	Description		Weight kg
XYP 2 F001	centair controller test unit		1.0
Supply pressure p ₁ 1)	1.3 ± 0.1 bar	Connection diagram	A03208
Output pressure p ₂	01.3 bar	Dimension drawing	M297100
Input pressure p_3 , p_4 , p_5 , p_6	0.21.0 bar	Fitting instructions	Manual (Accessories)




Accessoires

-XMP Plug-in pressure gauge for the Centair measuring ranges, see Section 68.

0297168 000Set of ancillary material for RCP test (Centair)0304100 001Service manual for Centair German, for XYP 20304100 003Service manual for Centair French, for XYP 20304100 003Service manual for Centair English for XYP 2

See Section 60 on regulations concerning the quality of supply air, especially at low ambient temperature.

Connection diagram



Dimension drawing

